

# Version history - Regio Ardo/Eedo

---

This document summarises the software updates for Regio Ardo/Eedo.

---

## Version 2.2-1-00

December 17th, 2025

Support for Regio RUX, improvements and added functionality.

See below for details.

- Support for Regio RUX Room Unit (*TP#28311*)  
Added support for the new Regio RUX room unit.
  - Support for Humidity control (*TP#45086*)  
Added control loop for Humidity, works same way as for CO2.
  - Regio Ardo/Eedo - Tooltip AT2 missing modbus address (*TP#40711*)  
Improved information in tooltip Application tool 2.
  - Regio Ardo 2 rooms: CO2 sensor is not read for Room 2 (*TP#41070*)  
Correction in CO2 sensor functionality for room 2.
  - Regio Ardo 2 rooms: "room unit not connected" false alarm (*TP#41071*)  
Solved issue with false alarm.
  - Application Tool 2 error message in section Modbus room unit (*TP#41075*)  
Solved issue with missing heading in Application tool 2.
  - Regio Ardo - Cooling valve settings room 2 (*TP#42162*)  
Solved issue with missing settings in Application tool 2.
  - Application Tool Regio 2.1-1-00 Actual values are not displayed (*TP#42682*)  
Solved issue with actual values for Heating and Cooling missing in Application tool 2.
  - Regio Eedo2.1-1-00 does not follow time scheduler (*TP#45495*)  
Solved issue where state was not changed according to the schedule set up in the time scheduler.
- 

## Version 2.2-1-00

Improvements and added functionality.

See below for details.

- Improved BACnet support (*TP#27631*)  
Support for renaming BACnet objects.
- Improved Afterblow function (*TP#35619*)  
Solved an issue where afterblow does not function with electric heater and change-over mode set to Cooling.
- Improved Afterblow function (*TP#27650*)  
Solved an issue where afterblow can be overridden by manual fan settings.
- Add removable walls function for Regio Eedo (*TP#31835*)

Possibility to connect five controllers (forming one zone) whereof one acting as a master controlling the other four.

- Support for generic Room Units (*TP#27628*)  
Connect room units from other brands via modbus.
- Documentation Improvements (*TP#22115*)  
Merged the Manual for Eedo and Ardo. Clarified when it is needed to fill in ELA.